

Keysight 16196A/B/C/D Parallel Electrode SMD Test Fixture

Notices

© Keysight Technologies
1999–2020

No part of this manual may be reproduced in any form or by any means (including electronic storage and retrieval or translation into a foreign language) without prior agreement and written consent from Keysight Technologies, Inc. as governed by United States and international copyright laws.

Trademark Acknowledgments

Manual Part Number

16196-90040

Edition

Edition 6, January 2020

Printed in Malaysia

Published by:

Keysight Technologies International
Japan G.K,
1-3-3 Higashikawasaki-cho
Chuo-ku
Kobe-shi, Hyogo, Japan

Warranty

THE MATERIAL CONTAINED IN THIS DOCUMENT IS PROVIDED “AS IS,” AND IS SUBJECT TO BEING CHANGED, WITHOUT NOTICE, IN FUTURE EDITIONS. FURTHER, TO THE MAXIMUM EXTENT PERMITTED BY APPLICABLE LAW, KEYSIGHT DISCLAIMS ALL WARRANTIES, EITHER EXPRESS OR IMPLIED WITH REGARD TO THIS MANUAL AND ANY INFORMATION CONTAINED HEREIN, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. KEYSIGHT SHALL NOT BE LIABLE FOR ERRORS OR FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES IN CONNECTION WITH THE FURNISHING, USE, OR PERFORMANCE OF THIS DOCUMENT OR ANY INFORMATION CONTAINED HEREIN. SHOULD KEYSIGHT AND THE USER HAVE A SEPARATE WRITTEN AGREEMENT WITH WARRANTY TERMS

COVERING THE MATERIAL IN THIS DOCUMENT THAT CONFLICT WITH THESE TERMS, THE WARRANTY TERMS IN THE SEPARATE AGREEMENT WILL CONTROL.

Technology Licenses

The hardware and/or software described in this document are furnished under a license and may be used or copied only in accordance with the terms of such license.

Declaration of Conformity

Declarations of Conformity for this product and for other Keysight products may be downloaded from the Web. Go to <http://www.keysight.com/go/conformity>. You can then search by product number to find the latest Declaration of Conformity.

U.S. Government Rights

The Software is “commercial computer software,” as defined by Federal Acquisition Regulation (“FAR”) 2.101. Pursuant to FAR 12.212 and 27.405-3 and Department of Defense FAR Supplement (“DFARS”) 227.7202, the U.S. government acquires commercial computer software under the same terms by which the software is customarily provided to the public. Accordingly, Keysight provides the Software to U.S. government customers under its standard commercial license, which is embodied in its End User License Agreement (EULA), a copy of which can be found at

<http://www.keysight.com/find/sweula> The license set forth in the EULA represents the exclusive authority by which the U.S. government may use, modify, distribute, or disclose the Software. The EULA and the license set forth therein, does not require or permit, among other things, that Keysight: (1) Furnish technical information related to commercial computer software or commercial computer software documentation that is not customarily provided to the public; or (2) Relinquish to, or otherwise provide, the government rights in excess of these rights customarily provided to the public to use, modify, reproduce, release,

perform, display, or disclose commercial computer software or commercial computer software documentation. No additional government requirements beyond those set forth in the EULA shall apply, except to the extent that those terms, rights, or licenses are explicitly required from all providers of commercial computer software pursuant to the FAR and the DFARS and are set forth specifically in writing elsewhere in the EULA. Keysight shall be under no obligation to update, revise or otherwise modify the Software. With respect to any technical data as defined by FAR 2.101, pursuant to FAR 12.211 and 27.404.2 and DFARS 227.7102, the U.S. government acquires no greater than Limited Rights as defined in FAR 27.401 or DFARS 227.7103-5 (c), as applicable in any technical data.

Safety Notices

CAUTION

A **CAUTION** notice denotes a hazard. It calls attention to an operating procedure, practice, or the like that, if not correctly performed or adhered to, could result in damage to the product or loss of important data. Do not proceed beyond a CAUTION notice until the indicated conditions are fully understood and met.

WARNING

A **WARNING** notice denotes a hazard. It calls attention to an operating procedure, practice, or the like that, if not correctly performed or adhered to, could result in personal injury or death. Do not proceed beyond a WARNING notice until the indicated conditions are fully understood and met.

Table of Contents

1. Installation Guide	
Incoming Inspection	5
Connecting the 16196A/B/C/D to a Measuring Instrument	10
2. Product Overview	
Product Overview	13
Functions	15
Names of Accessories and Functions	16
3. Operation	
Flow of Measurements	19
Selecting and Changing the Insulator Assembly	20
Setting the Electrical Length	24
Performing Fixture Compensation	25
Measuring Open Compensation Data	25
Measuring Short Compensation Data	27
Connecting and Measuring DUTs	29
Removing the DUT	30
4. User Maintenance	
Overview	31
The Necessity of User Maintenance	31
User Maintenance Flow	32
Cleaning	34
Places Requiring Cleaned	34
Cleaning Methods	35
Wear Check	37
Example of User Limit Values Setting	37
Reference Value Acquisition.	39
Measuring Impedance Shift	41
Check Sheet	42
Check Sheet Fill-Out Example	42
Electrode Wear Check	43
Short Plate Wear Check	44
Parts Replacement	45
Procedure for Replacement	45
Check Following Replacement.	45
Assembling Check	46

Contents

Electrode Check	46
Short Plate Check	49
5. Specifications and Supplemental Performance Characteristics	
Specifications	52
Supplemental Performance Characteristics	53
Additional Error	53
6. Service	
Replaceable Parts	60
Block Assembly	61
Cap.	64
Other Parts.	66
Maintenance Kit.	67
16196U Maintenance Kit.	67
Replacement Procedure	68
Lower Electrode.	69
Insulator.	71
Upper Electrode.	72
Assembling Check	74
Method Using Network Analyzer	74

1 Installation Guide

In this chapter, the procedures required from the time the 16196A/B/C/D Parallel Electrode SMD Test Fixture arrives until its use begins are described.

Incoming Inspection

Inspect the shipping container for damage. If the shipping container or cushioning material is damaged, it should be kept until the contents of the shipment have been checked for completeness and the 16196A/B/C/D has been checked mechanically and electrically.

The shipment should contain everything listed in [Table 1-1](#) to [Table 1-4](#). If the contents are incomplete or if there is mechanical damage or defect, notify the nearest Keysight Technologies office. If the shipping container is damaged or the cushioning material shows signs of unusual stress, notify the carrier as well as the Keysight Technologies office. Keep the shipping materials for the carrier's inspection.

NOTE

When the equipment is used for the first time following purchase, “Wear Check” should be conducted. This “Wear Check” is required for keeping the measurement accuracy. Refer to [“Reference Value Acquisition” on page 39](#) in [“Wear Check”](#) for details.

Figure 1-1 16196A/B/C/D Contents




Table 1-1

16196A Package Contents

No	Keysight Part Number	Qty	Description
1	-	1	16196A Parallel Electrode SMD Test Fixture
-	16196-60112	1	Insulator Assembly $\phi 1.34$ ¹
2	16196-60113	1	Insulator Assembly $\phi 1.14$
	16196-60114	1	Insulator Assembly $\phi 1.08$
3	16196-29002	1	Open Plate ²
4	16196-29026	1	Short Plate ²
5	16196-24004	1	Push Ring
6	8710-2081	1	Tweezers ³
7	5182-7586	1	Cleaning Rod
8	8710-0909	1	Wrench
9	16193-60002	1	Magnifying Glass ³
10	16196-60150	1	Carrying Case
11	Option ABA	1	Operation and Service Manual (This manual) ⁴

1. Mounted in the Test Fixture when shipped from the factory.
2. The Open Plate and Short Plate are packed in a single case and shipped. Refer to **"Maintenance Kit" on page 67** for replaceable part.
3. Furnished with Option 710.
4. The manual is furnished only Option ABA is ordered.

Table 1-2

16196B Package Contents

No	Keysight Part Number	Qty	Description
1	-	1	16196B Parallel Electrode SMD Test Fixture
-	16196-60212	1	Insulator Assembly $\phi 0.85$ ¹
2	16196-60213	1	Insulator Assembly $\phi 0.75$
	16196-60214	1	Insulator Assembly $\phi 0.68$
3	16196-29002	1	Open Plate ²
4	16196-29027	1	Short Plate ²
5	16196-24004	1	Push Ring

Table 1-2

16196B Package Contents

No	Keysight Part Number	Qty	Description
6	8710-2081	1	Tweezers ³
7	5182-7586	1	Cleaning Rod
8	8710-0909	1	Wrench
9	16193-60002	1	Magnifying Glass ³
10	16196-60250	1	Carrying Case
11	Option ABA	1	Operation and Service Manual (This manual) ⁴

1. Mounted in the Test Fixture when shipped from the factory.
2. The Open Plate and Short Plate are packed in a single case and shipped. Refer to **"Maintenance Kit" on page 67** for replaceable part.
3. Furnished with Option 710.
4. The manual is furnished only Option ABA is ordered.

Table 1-3

16196C Package Contents

No	Keysight Part Number	Qty	Description
1	-	1	16196C Parallel Electrode SMD Test Fixture
-	16196-60312	1	Insulator Assembly $\phi 0.48$ ¹
3	16196-29002	1	Open Plate ²
4	16196-29028	1	Short Plate ²
5	16196-24004	1	Push Ring
6	8710-2081	1	Tweezers ³
7	5182-7586	1	Cleaning Rod
8	8710-0909	1	Wrench
9	16193-60002	1	Magnifying Glass ³
10	16196-60350	1	Carrying Case
11	Option ABA	1	Operation and Service Manual (This manual) ⁴

1. Mounted on the Test Fixture when shipped from the factory.
2. The Open Plate and Short Plate are packed in a single case and shipped. Refer to **"Maintenance Kit" on page 67** for replaceable part.
3. Furnished with Option 710.
4. The manual is furnished only Option ABA is ordered.

Table 1-4

16196D Package Contents

No	Keysight Part Number	Qty	Description
1	-	1	16196D Parallel Electrode SMD Test Fixture
-	16196-60414	1	Insulator Assembly $\phi 0.30$ ¹
2	16196-60412	1	Insulator Assembly $\phi 0.34$
3	16196-29002	1	Open Plate ²
4	16196-29030 ³	1	Short Plate ²
5	16196-24004	1	Push Ring
6	8710-2081	1	Tweezers ⁴
7	5182-7586	1	Cleaning Rod
8	8710-0909	1	Wrench
9	16193-60002	1	Magnifying Glass ⁴
10	16196-60450	1	Carrying Case
11	Option ABA	1	Operation and Service Manual (This manual) ⁵

1. Mounted in the Test Fixture when shipped from the factory.
2. The Open Plate and Short Plate are packed in a single case and shipped. Refer to **"Maintenance Kit" on page 67** for replaceable part.
3. The part number is different from that of the replacement part. When you order it for user maintenance, refer to **Table 6-1 on page 62**.
4. Furnished with Option 710.
5. The manual is furnished only Option ABA is ordered.

Connecting the 16196A/B/C/D to a Measuring Instrument

To connect the 16196A/B/C/D Test Fixture to a measuring instrument, it is necessary to use an adapter that fits the measuring instrument.

The 16196A/B/C/D Test Fixture is suitable for use with a high frequency LCR Meter or Impedance Analyzer. **Table 1-5** lists the appropriate combination of measuring instrument and adapter.

Table 1-5 **Measuring Instruments and Adapters**

Instrument	Adapter
E4991A	Test Head (supplied with the E4991A)
E4991B	Test Head (supplied with the E4991B)
E4982A	Test Head (supplied with the E4982A), Test Fixture Stand (Opt. 710) and 3.5mm-7mm Coaxial Adapter (Opt. 720)
E4990A-120	42942A terminal adapter
E5061B-3L3/3L4/3L5 with Opt. 005	16201A

16196A/B/C/D Test Fixture can be connected to instruments with the 4-terminal pair configuration.

NOTE

Some instruments require calibration at the 7-mm connector. Perform calibration at the 7-mm connector before connecting a test fixture. See the operation manual of the instrument for more details.

The general procedure for mounting the Test Fixture on the adapter is as shown below. (For details, see the Manual supplied with each adapter.)


- Step 1.** Turn the adapter's 7-mm connector in the counterclockwise direction when viewed from above and screw the connection sleeve in fully.
- Step 2.** Align the test fixture with the adapter's mount post and 7-mm connector and set it gently in place.
- Step 3.** Turn the adapter's 7-mm connector counterclockwise, connecting the bottom of the test fixture with the connector.

NOTE

To make a firm connection with the test fixture, use the torque wrench (size: 3/4 inch, torque: 12 lb-in, Keysight part number: 8710-1766) to fasten the adapter's 7-mm connector.

Figure 1-2

Installing the Test Fixture



16196abcqj0101

Installation Guide
Connecting the 16196A/B/C/D to a Measuring Instrument

2 Product Overview

Product Overview

The 16196A, 16196B, 16196C, and 16196D are test fixtures for measuring chip components. They enable chip type capacitors, inductors and other components to be measured with high precision and measurement repeatability. The 16196A/B/C/D also is compatible with measuring frequencies up to 3GHz. The 16196A is for size 1608 parts¹, the 16196B is for size 1005 parts¹, the 16196C is for size 0603parts¹, and the 16196D is for size 0402 parts¹.

Figure 2-1 Product Overview (The photograph shows the 16196B.)




The product appearance is the same for the 16196A, 16196B and 16196C. Only the cap shape for the 16196D is different.

1. These sizes, 1608, 1005, 0603, and 0402, are all nominal sizes in millimeters.

Figure 2-2

Electrode Structure



After passing through the DUT (Device Under Test), the current flows to the outer conductor via the cap electrode and returns to the outer conductor of the 7-mm connector. Through this structure, the ideal shield structure is formed.

Functions

The names of each part of the 16196A/B/C/D are shown in **Figure 2-3**.

Figure 2-3 Names of Parts




Table 2-1 Names of Parts and Functions

No.	Name	Function
1	Cap	This is the UPPER electrode.
2	DUT Insertion Hole	Forms a cylindrical structure made with an insulator and holds the DUT from the sides.
3	Magnifying Glass ¹²	Enlarges the DUT and the insulator hole area.

1. Furnished with Option 710.
2. The magnifying glass is packed separately from the 16196A/B/C/D body. Connect it as shown in **Figure 2-3**.

Names of Accessories and Functions

Figure 2-4 Accessories




Table 2-2 Names of Accessories and Functions














No	Name	Function
1	Open Plate	Used when correcting for an open circuit.
2	Short Plate	Used when correcting for a short circuit.
3	Insulator Assembly	Used to change assemblies when measuring DUTs with different shapes.
4	Push Ring	Supplementary tool used when removing DUTs.
5	Cleaning Rod	Cleans the electrodes.
6	Wrench	For removing hex nuts.
7	Tweezers ¹	Used to handle the open plate, short plate, and DUTs, etc.

1. Furnished with Option 710.

Insulator Assembly

In order to handle DUTs with differing shapes, the 16196A and 16196B each come with 3 types of insulator assembly, the 16196C comes with 1 insulator assembly, and the 16196D comes with two types of insulator assembly. Each of these insulator assemblies has little marks engraved in them to enable identification of each model and hole diameter. There are marks on the back of the insulator assemblies to identify the model and there are marks on the front to identify the hole diameter.

Insulator Assembly identifications

Keysight Model No	Back	Front		
16196A		 $\phi 1.34$	 $\phi 1.14$	 $\phi 1.08$
16196B		 $\phi 0.85$	 $\phi 0.75$	 $\phi 0.68$
16196C		 $\phi 0.48$		
16196D		 $\phi 0.30$	 $\phi 0.34$	

3 Operation

This chapter describes preparations and fixture compensation when using the 16196A/B/C/D to take measurements as well as DUT connection and measuring methods.

Flow of Measurements

Follow the steps below when performing measurements of DUTs with the 16196A/B/C/D.

1. **Selecting and Changing the Insulator Assembly**
Select an insulator assembly that is appropriate for the shape of the measured DUT and replace the insulator assembly in the fixture.
2. **Setting the Electrical Length**
Set the fixture's electrical length in the measuring instrument you will be using.
3. **Performing Fixture Compensation**
Measure the data for open compensation and measure the data for short compensation. When performing measurements with higher precision, carry out "Fixture compensation for higher precision measurements".
4. **Connecting and Measuring the DUT**
Connect the DUT and perform measurements.

Settings of the electrical length and fixture compensation differ depending on the measuring instrument used. Refer to the Operation Manual for the measuring instrument that you are using.

NOTE

The 16196A/B/C/D requires frequent wear checks to keep the best measurement accuracy. When the equipment is used for the first time following purchase or part replacement, "Wear Check" should be conducted. Refer to **"Wear Check" on page 37** for details.

Selecting and Changing the Insulator Assembly

Select an insulator assembly that corresponds to the shape of the DUT being measured and replace the insulator assembly in the fixture.

CAUTION

An exclusive type of insulator assembly is supplied with each model. Do not use an insulator assembly from a different model.

Step 1. Select an insulator assembly that is appropriate for the shape of the DUT to be measured.

To take accurate and repeatable measurements, it is necessary for the DUT to be placed in the DUT insertion hole and be stable. For that reason, the 16196A and 16196B each are provided with 3 types of insulator assembly which have DUT insertion holes with different diameters (the 16196C has only one type of insulator assembly, and the 16196D has two types of insulator assembly). Select an insulator assembly that will create the narrowest gap between the DUT and the DUT insertion hole.

Figure 3-1 DUT and DUT Insertion Hole Diameter




Table 3-1 Insulator Assembly Specifications

	Insulator Assembly	Example of Corresponding Chip (mm)		
		Length (L)	Width (W)	Height (H)
16196A	$\phi 1.34$	1.6	0.8	0.8
	$\phi 1.14$	1.6	0.8	0.6
	$\phi 1.08$	1.6	0.8	0.5

Table 3-1

Insulator Assembly Specifications

	Insulator Assembly	Example of Corresponding Chip (mm)		
		Length (L)	Width (W)	Height (H)
16196B	$\phi 0.85$	1.0	0.5	0.5
	$\phi 0.75$	1.0	0.5	0.35
	$\phi 0.68$	1.0	0.5	0.35
16196C	$\phi 0.48$	0.6	0.3	0.3
16196D	$\phi 0.30$	0.4	0.2	0.13 or 0.2 ¹
	$\phi 0.34$	0.4	0.2	0.2 ¹

1. When you measure a 0.4 x 0.2 x 0.2 DUT, first check whether it fits in the $\phi 0.30$ insulator assembly. Only if it does not, use the $\phi 0.34$ insulator assembly.

NOTE

The number of the insulator assembly doesn't indicate the maximum diameter of the DUT insertion hole that can insert the cylindrical device.


NOTE

If the gap between the DUT and the insulator is large, the measurement accuracy and repeatability decrease. Select an insulator assembly that is appropriate for the shape of the DUT to be measured.

- Step 2.** Replace the insulator assembly in the fixture with the selected insulator assembly.
Loosen the 2 screws used to fasten the insulator assembly with the hex wrench and take them out, then remove the insulator assembly.

Figure 3-2

Removing the Insulator Assembly



NOTE


If the insulator assembly is difficult to remove, turn the fixture over and remove the insulator assembly by letting it fall out.

CAUTION

There is danger of the measuring precision and repeatability being adversely affected, and thus do not touch the lower electrode with your hands or damage it in any way.

- Step 3.** Mount the insulator assembly you have selected, and tighten the screws to secure it. Be sure to contact the insulator assembly with the bottom surface securely before tightening the screws.

Figure 3-3 Installing the Insulator Assembly



- Step 4.** Connect the test fixture to the measuring instrument.
Connect the test fixture to the instrument in accordance with [“Connecting the 16196A/B/C/D to a Measuring Instrument” on page 10](#) in Chapter 1.

Setting the Electrical Length

Set the electrical length in the measuring instrument. For the electrical length setting method, see the Operation Manual for the measuring instrument you are using. The electrical lengths for the 16196A/B/C/D are as shown below.

Table 3-2 Electrical Length

Model	Electrical Length [mm]
16196A	26.2
16196B	26.9
16196C	27.1
16196D	27.3

Performing Fixture Compensation

In order to perform more accurate measurements, before beginning the measurement procedure, it is necessary to compensate the fixture. For the 16196A/B/C/D, perform measurements of the data for open compensation and of the data for short compensation.

NOTE

The 16196A/B/C/D requires frequent wear checks to keep the best measurement accuracy. When the equipment is used for the first time following purchase or part replacement, “Wear Check” should be conducted. Refer to [“Wear Check” on page 37](#) for details.

NOTE

If there are temperature fluctuations which exceed a temperature range of $\pm 5^{\circ}\text{C}$ after fixture compensation has been carried out, then perform fixture compensation again.

Measuring Open Compensation Data

Set the fixture in the open state using the open plate supplied.

Step 1. Remove the cap.

CAUTION


Make sure there is no dirt or other foreign matter in the DUT insertion hole.

Step 2. Using the Tweezers, place the open plate on top of the insulator assembly. Set the open plate with the protruding surface down.

CAUTION

Handle the open plate with Tweezers. If dirt, etc. gets on it, measuring precision and repeatability may be adversely affected.

Figure 3-4 Setting the Open State Using the Open Plate



Step 3. Fit the cap in place with the mark toward the front, and turn it to the right until it is locked.

Step 4. Take measurements of the data for open compensation in accordance with the Operation Manual for the measuring instrument you are using.

Measuring Short Compensation Data

Set the fixture in the short state using the short plate supplied.

- Step 1.** Remove the cap. Take out the open plate used to measure the open compensation data.

CAUTION

Make sure there is no dirt or other foreign matter in the DUT insertion hole.

CAUTION


An exclusive type of short plate is supplied with each model. Do not use a short plate from a different model.

- Step 2.** Place the short plate on the insulator assembly with tweezers. Place the rod-shaped protrusion of the short plate downward, and insert it into the DUT insertion hole.

CAUTION

Handle the short plate with Tweezers. If dirt, etc. gets on it, measuring precision and repeatability may be adversely affected.

Figure 3-5 Setting the Short State Using the Short Plate



- Step 3.** Fit the cap in place with the mark toward the front, and turn it to the right until it is locked.

- Step 4.** Take measurements of the data for short compensation in accordance with the Operation Manual for the measuring instrument you are using.

NOTE

Residual inductance for the Short Plate is as follow.

Model	Residual Inductance [nH]
16196A	0.43
16196B	0.27
16196C	0.16
16196D	0.11

Connecting and Measuring DUTs

Connect DUTs to the electrodes and take measurements.

CAUTION

Do not connect a DUT, which has an incompatible size.

Step 1. Remove the cap.


CAUTION

Make sure there is no dirt or other foreign matter in the DUT insertion hole.

Step 2. Insert the DUT into the insulator hole with tweezers.

Use a magnifying glass to check that the DUT is inserted deeply enough into the insulator hole for it to contact the bottom electrode.

Figure 3-6 Connecting a DUT




Step 3. Fit the cap in place with the mark toward the front, and turn it to the right until it is locked.

Step 4. Take measurements in accordance with the Operation Manual for the measuring instrument you are using.

Removing the DUT

Use the push ring when removing the DUT.

Figure 3-7 Removing the DUT Using the Push Ring



Press the insulator assembly down using the push ring. When this is done, the lower electrode will push up the DUT and you will be able to remove it. Measurements can also be taken with the push ring placed as is on the insulator assembly.

4 User Maintenance

Overview

The Necessity of User Maintenance

The measurement performance of the fixture decreases slightly each time measurement is repeated. This is due to contamination of the contacting sections by solder, etc. and mechanical wear and distortion caused by repeated use. Consequently, to maintain satisfactory measurement results, it is important to maintain the contacting sections in good condition and take appropriate measures before wear or distortion occurs. To accomplish this it is necessary to monitor the fixture and perform maintenance of the various items as described in **“User Maintenance Flow” on page 32.**

Because deterioration of the fixture seriously affects the measurement results when measuring minute values or performing measurements with a high accuracy, proper maintenance of the fixture is particularly important in these cases. Depending on the required measurement performance, it may be necessary to take measures such as establishing more rigorous evaluation standards and perform maintenance more frequently.

The upper and lower electrodes and the short plate are consumable products. These are the fixture construction parts that tend to have the greatest effect on the measurement results. During measurement, solder from the DUT tends to adhere to the upper and lower electrodes, causing gradual deterioration of the electrodes. The short plate part is used for creating a zero-standard during fixture compensation and distortion or contamination of the short plate therefore directly affects the measurement result. Focusing on the upper and lower electrodes and the short plate, this chapter explains the general aspects of user maintenance.

User Maintenance Flow


Figure 4-1 shows the flowchart of the user maintenance. The overview of the each maintenance item is explained below.

Table 4-1

Maintenance Items

Item		Frequency	Item
Cleaning		Several times daily	Cleaning of fixture
Wear Check	Setting the user limit	When the product is received and when you need	Set the user limit to the required measurement accuracy and the measurement condition.
	Measuring reference value	When the product is received and after parts replacement	Measure Ls and Rs of the fixture and set it the reference value
	Measuring impedance shift	daily and before fixture compensation	Measure Ls and Rs of the fixture and calculate the shift from the reference value.
Parts Replacement		When the wear check is failed.	Replacement of worn parts
Assembling Check		After parts replacement	Measure Ls and Rs to confirm that the fixture is assembled correctly.

Figure 4-1 Flowchart of User Maintenance



Cleaning

If the electrodes and insulator assembly become dirty, measuring accuracy and repeatability will decrease. Also, if dirt adheres to the surfaces of the body, it will become impossible to remove the cap smoothly. In order to ensure measurement with high accuracy, be sure to perform cleaning periodically.


Places Requiring Cleaned

Place, which need to be cleaned, are as follows.

- Upper Electrode (Figure 4-2 (1))
- Cap Inside (Figure 4-2 (2))
- Lower Electrode (Figure 4-2 (3))
- Insulator Assembly recessed part (Figure 4-2 (4))
- Body side surfaces (Figure 4-2 (5))
- Short Plate
- Open Plate

Figure 4-2

Places to be Cleaned




Cleaning Methods

Upper Electrode (Figure 4-2 (1)), Insulator Assembly (Figure 4-2 (4)), Open Plate, Short Plate

Use the Cleaning Rod (Keysight parts number 5182-7586) for the cleaning. Use the white rubber part of the cleaning rod to remove dirt from all contacting surfaces of the above-mentioned parts. Be careful not to scratch or damage the parts when removing the dirt.

Figure 4-3

Cleaning Rod



Dirt tends to adhere to the upper electrode and short plate parts in particular. Meticulous cleaning of these parts is recommended.

CAUTION

The front of the short plate has a sharp edge, so take adequate precautions when cleaning it.

CAUTION

Do not use a file or similar object to remove dirt, as this will affect measurement accuracy and repeatability.

NOTE

If the dirt cannot be removed, replace the part. For replacement method, see the sections “Parts Replacement” and “Procedure for Replacement”.

Lower Electrode (Figure 4-2 (3))

Use the Cleaning Rod (Keysight parts number 5182-7586) for the cleaning. First use the push ring to press down the insulator assembly. While maintaining this condition, use the white rubber part of the cleaning rod to remove dirt from the contacting parts of the lower electrode. Be careful not to scratch or damage the parts when removing the dirt.

Dirt tends to adhere to the lower electrode parts in particular. Meticulous cleaning of these parts is recommended.

CAUTION

Do not use a file or similar object to remove dirt, as this will affect measurement accuracy and repeatability.

NOTE

If the dirt cannot be removed, replace the part. For replacement method, see the sections “**Parts Replacement**” and “**Procedure for Replacement**”.

Cap Inside (**Figure 4-2 (2)**), Body Side Surfaces (**Figure 4-2 (5)**)

Wipe dirt off using a soft cloth, etc.

NOTE

When removing dirt, always be careful to clean so that the electrodes and insulator assembly are not damaged.

Wear Check

The wear check allows you to obtain an idea about the deterioration of the fixture in order to ensure that the desired measurement accuracy is obtained. This check comprises “User Limit Setting”, “**Reference Value Acquisition**” and “**Measuring Impedance Shift**”. Using a desired frequency, the impedance (R_s , L_s) of the fixture itself is measured. It is recommended to use a frequency that is also used under the conditions where the fixture is normally used.

Normally, “User Limit Setting” should be conducted under the following circumstances.

- When the equipment is used for the first time following purchase.
- When the required measurement accuracy is changed.

Normally, “**Reference Value Acquisition**” should be conducted under the following circumstances.

- When the equipment is used for the first time following purchase.
- Following replacement of parts.

Normally, “**Measuring Impedance Shift**” should be conducted under the following circumstances.

- Once daily and before fixture compensation is performed.

Example of User Limit Values Setting

It is necessary to decide wear check user limit values suitable for the DUT and the demanded measurement accuracy. An example follows below.

To measure the inductors L: 10nH and Q: 10 at a frequency (f) of 100MHz with a measurement accuracy degree of 20%;

L:	10nH
Q:	10
Frequency:	100MHz
Demanded Accuracy:	20% for both L and Q

Using the above conditions, the inductor's reactance X and resistance R are determined in the following manner.

$$X = 2\pi fL = 6 \Omega$$
$$R = X/Q = 0.6 \Omega$$

From $Q = X/R = 2\pi fL/R$ we understand that when R changes 20% (100m Ω) Q should be approximately 20%, and when L changes 20% (2nH), L and Q both change 20%. Accordingly, in order to measure both L and Q with a measurement accuracy of 20% or less, at least the error of L and R must be less than 2nH and 120m Ω , respectively. While remembering that L and R

change together and keeping in mind other error factors than the deterioration of the fixture, the respective values should be set to 25% in this example, i.e., 500pH and 30m Ω .

CAUTION

Use the same user limit values for “Measuring Impedance Shift”.

NOTE

The above is just an example. The methods to determine the user limit vary with the measurement conditions and the DUT, etc.

NOTE

In actually testing, a part of the effect of electrode wear is canceled by the SHORT compensation. It is recommended, however, to set the user limit as shown in this example as the deviation from the reference value can be used to deal with all the things affecting the measured values.

Please enter the user limit values in the “Check Sheet” (Page 43, Page 44). See “Check Sheet Fill-Out Example” on page 42 for an example of how this is done.

Reference Value Acquisition

The impedance (Rs, Ls) of the fixture itself should be measured before deterioration sets in. It is recommended to use a measurement frequency that is used under the conditions where the fixture is normally used.

Normally, the reference value should be measured under the following circumstances.

- When the product is introduced.
- Following replacement of parts.

Required Tools

- 1.5-mm hex wrench (provided accessory)
- Short plate (provided accessory)
- Impedance measuring instrument (with 7-mm connector and calibrated)

Table 4-2 Setting of Measuring Instrument

Measurement Condition	Set Value
Electrical Length	16196A: 26.2mm 16196B: 26.9mm 16196C: 27.1mm 16196D: 27.3mm
Measurement Parameter	Ls, Rs
OSC Level	500mV
Point Averaging	32

NOTE

To make the same settings as given in the above table, refer to the Operation Manual for the measuring instrument.

CAUTION

The measuring instrument's fixture compensation function should be set to OFF.

Acquisition Procedure (Electrode Wear Check Reference Value)

- Step 1.** Remove the cap and ensure that nothing is inserted into the fixture.
- Step 2.** Clean the fixture's upper and lower electrodes as described in "Cleaning" on page 34.
- Step 3.** Connect the fixture to the 7-mm connector.

Step 4. Place the cap on the fixture body.

Step 5. In order to contact the upper electrode and the lower electrode, use the provided hex wrench to turn the screw at the top of the cap approximately 6 turns to the left.

NOTE

In case of the 16196D, please omit the step 5.

Step 6. Measure Rs and Ls as described in the Operation Manual for the measuring instrument.

Step 7. Record the read values as the reference values in the “Check Sheet” (Page 43).

Step 8. Calculate the upper limit value and the lower limit value from the previously set user limits and the reference values obtained here. Record these in the “Check Sheet”.

Step 9. Tighten the screw on top of the cap loosened in Step 5.

NOTE

In case of the 16196D, please omit the step 9.

Acquisition Procedure (Short Plate Wear Check Reference Value)

Step 1. Clean the short plate as described in “Cleaning” on page 34.

Step 2. Remove the cap and place the short plate with the protruding surface down on the insulator assembly.

Step 3. Place the cap on the fixture body.

Step 4. Measure Rs and Ls as described in the Operation Manual for the measuring instrument.

Step 5. Record the read values as the reference values in the “Check Sheet” (Page 44).

Step 6. Calculate the upper limit value and the lower limit value from the previously set user limits and the reference values obtained here. Record these in the “Check Sheet”.

Measuring Impedance Shift

Measuring the impedance of the fixture with the upper and lower electrodes in contact should check the electrode wear.

Normally, this check should be conducted under the following circumstances.

- Once daily and before fixture compensation.

Required Tools

- 1.5-mm hex wrench (provided accessory)
- Impedance measuring instrument (with 7-mm connector and calibrated)

CAUTION

The measuring instrument's fixture compensation function should be set to OFF. Also, other settings should be the same as those used for "Reference Value Acquisition".

Procedure (Electrode Wear Check)

- Step 1.** Clean the electrodes as described in "Cleaning" on page 34.
- Step 2.** Set the measuring instrument and measure in the same way as for "Acquisition Procedure (Electrode Wear Check Reference Value)" on page 39.
- Step 3.** Record the Rs and Ls measured values as pass-fail in the "Check Sheet" (Page 43).
- Step 4.** If the result is unacceptable, replace both the upper and the lower electrode.

Procedure (Short Plate Wear Check)

- Step 1.** Clean the short plate as described in "Cleaning" on page 34.
- Step 2.** Set the measuring instrument and measure in the same way as for "Acquisition Procedure (Short Plate Wear Check Reference Value)" on page 40.
- Step 3.** Enter the Rs and Ls measured values as pass-fail in the "Check Sheet" (Page 44).
- Step 4.** If the result is unacceptable, replace the short plate.

Check Sheet

Check Sheet Fill-Out Example

The following example shows how the check sheet is filled out following electrode wear check. Fill out the sheet in the same manner for short plate wear check.

Electrode Wear Check Fill-Out Example

Table 4-3 Reference Value and User Limit Values Fill-Out Example

Frequency ¹	Measurement Parameter	Reference Value ² [a]	User Limit Value ³ [b]	Lower Limit [a-b]	Upper Limit [a+b]
100 MHz	Rs	90mΩ	30mΩ	60mΩ	120mΩ
	Ls	-290 pH	500pH	-790pH	210pH
800 MHz	Rs	310 mΩ	40mΩ	270mΩ	350mΩ
	Ls	-260 pH	400pH	-660pH	140pH

1. Set by the user as desired.
2. Record values obtained at the time of **“Reference Value Acquisition”** on page 39.
3. See also **“Example of User Limit Values Setting”** on page 37.

Table 4-4 Check History Fill-Out Example

Date	Frequency	Measurement parameter	Measured Value	Pass/Fail
Oct./11/1999 9:30	100 MHz	Rs	100mΩ	Pass
		Ls	-320pH	Pass
Oct./11/1999 9:35	800 MHz	Rs	345mΩ	Pass
		Ls	-360pH	Pass
Oct./12/1999 9:30	100 MHz	Rs	105mΩ	Pass
		Ls	-340pH	Pass
Oct./12/1999 9:35	800 MHz	Rs	355mΩ	Fail ¹
		Ls	-320pH	Pass

1. When the result is unacceptable, replace the part.

Electrode Wear Check

Table 4-5 Reference Value and User Limit Values

Frequency	Measurement Parameter	Reference Value [a]	User Limit Value [b]	Lower Limit [a - b]	Upper Limit [a + b]
	Rs	mΩ	mΩ	mΩ	mΩ
	Ls	pH	pH	pH	pH
	Rs	mΩ	mΩ	mΩ	mΩ
	Ls	pH	pH	pH	pH

Table 4-6 Check History

Date	Frequency	Measurement Parameter	Measured Value	Pass/Fail
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	

Short Plate Wear Check

Table 4-7 Reference Value and User Limit Values

Frequency	Measurement Parameter	Reference Value [a]	User Limit Value [b]	Lower Limit [a - b]	Upper Limit [a + b]
	Rs	mΩ	mΩ	mΩ	mΩ
	Ls	pH	pH	pH	pH
	Rs	mΩ	mΩ	mΩ	mΩ
	Ls	pH	pH	pH	pH

Table 4-8 Check History

Date	Frequency	Measurement Parameter	Measured Value	Pass/Fail
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	
		Rs	mΩ	
		Ls	pH	

Parts Replacement

The replacement of parts is explained in the following.

Procedure for Replacement

Refer to **“Replaceable Parts” on page 60** and **“Replacement Procedure” on page 68** when replacing parts.

A maintenance kit containing 5 pieces is available for replacement of upper and lower electrodes and the short plate. For details, see **“Maintenance Kit” on page 67**.

Check Following Replacement

Following replacement of parts, it is necessary to confirm that the fixture has been correctly assembled. Please conduct the **“Assembling Check” on page 46**.

Assembling Check

Following replacement of parts, confirm that the fixture has been correctly assembled. The assembling check consists of “**Electrode Check**” and “**Short Plate Check**”, Measure the impedance (Rs, Ls) of both at 100MHz and 1GHz.

Normally, this check should be conducted under the following circumstances.

- Following replacement of parts.

Electrode Check

It should be checked whether the fixture is correctly assembled by measuring the impedance (Rs, Ls) of the fixture itself with the upper and lower electrodes in contact.

Required Tools

- 1.5-mm hex wrench (provided accessory)
- Impedance measuring instrument (with 7-mm connector and calibrated)

Table 4-9

Setting of Measuring Instrument

Measurement Condition	Set Value
Electrical Length	16196A: 26.2mm
	16196B: 26.9mm
	16196C: 27.1mm
	16196D: 27.3mm
Measurement Parameter	Ls, Rs
OSC Level	500mV
Point Averaging	32

NOTE

To make the same settings as given in the above table, refer to the Operation Manual for the measuring instrument.

Procedure

- Step 1.** Remove the cap and ensure that nothing is inserted into the fixture.
- Step 2.** Clean the fixture’s upper and lower electrodes as described in “**Cleaning**” on page 34.
- Step 3.** Connect the fixture to the 7-mm connector.
- Step 4.** Place the cap on the fixture body.

Step 5. In order to contact the upper electrode and the lower electrode, use the provided hex wrench to turn the screw on the top of the cap approximately 6 turns to the left.

NOTE

In case of the 16196D, please omit the step 5

Step 6. Measure Rs and Ls at 100MHz and 1GHz in this state.

Step 7. Confirm that the Rs and Ls values are within the limits given in the table below. If the results are outside the limit range, first check the attachment of the upper and lower electrode. If these are correctly attached but the results still remain outside the limit range, the fixture main body may be damaged. In this case, please contact a Keysight Technologies Sales or Service office.

Step 8. Tighten the screw on top of the cap loosened in Step 5.

NOTE

In case of the 16196D, please omit the step 8.

Table 4-10

Electrode Check and Limits (16196A)

Parameter	Frequency	Limit (Absolute value)
100MHz	Rs	30m Ω ~ 150m Ω
	Ls	-500pH ~ 0pH
1GHz	Rs	100m Ω ~ 480m Ω
	Ls	-500pH ~ 0pH

Table 4-11

Electrode Check and Limits (16196B)

Parameter	Frequency	Limit (Absolute value)
100MHz	Rs	40m Ω ~ 160m Ω
	Ls	-400pH ~ 0pH
1GHz	Rs	120m Ω ~ 510m Ω
	Ls	-400pH ~ 0pH

Table 4-12

Electrode Check and Limits (16196C)

Parameter	Frequency	Limit (Absolute value)
100MHz	Rs	40m Ω ~ 170m Ω
	Ls	-300pH ~ 100pH

Table 4-12 Electrode Check and Limits (16196C)

Parameter	Frequency	Limit (Absolute value)
1GHz	Rs	120m Ω ~ 540m Ω
	Ls	–300pH ~ 100pH

Table 4-13 Electrode Check and Limits (16196D)

Parameter	Frequency	Limit (Absolute value)
100MHz	Rs	40m Ω ~ 250m Ω
	Ls	–300pH ~ 350pH
1GHz	Rs	80m Ω ~ 810m Ω
	Ls	–300pH ~ 200pH

Short Plate Check

Measuring the fixture's impedance with the short plate in place should check the condition of the short plate.

CAUTION

“Short Plate Check” should be performed after the **“Electrode Check”** has been completed.

Required Tools

- 1.5-mm hex wrench (provided accessory)
- Impedance measuring instrument (with 7-mm connector and calibrated)

Table 4-14

Setting of Measuring Instrument

Measurement Condition	Set Value
Electrical Length	16196A: 26.2mm
	16196B: 26.9mm
	16196C: 27.1mm
	16196D: 27.3mm
Measurement Parameter	Ls, Rs
OSC Level	500mV
Point Averaging	32

NOTE

To make the same settings as given in the above table, refer to the Operation Manual for the measuring instrument.

Procedure

- Step 1.** Clean the short plate as described in **“Cleaning” on page 34**.
- Step 2.** Remove the cap and place the short plate with the protruding surface down on the insulator assembly.
- Step 3.** Place the cap on the fixture body and fasten it.
- Step 4.** Measure Rs and Ls at 100MHz and 1GHz in this condition.

Step 5. Confirm that the Rs and Ls values are within the representative values given in the table below. If the results are outside the limit range, please replace the short plate.

Table 4-15 Short Plate Check and Limits (16196A)

Parameter	Frequency	Limit (Absolute value)
100MHz	Rs	30m Ω ~ 160m Ω
	Ls	200pH ~ 800pH
1GHz	Rs	100m Ω ~ 510m Ω
	Ls	200pH ~ 600pH

Table 4-16 Short Plate Check and Limits (16196B)

Parameter	Frequency	Limit (Absolute value)
100MHz	Rs	40m Ω ~ 170m Ω
	Ls	100pH ~ 600pH
1GHz	Rs	120m Ω ~ 540m Ω
	Ls	100pH ~ 400pH

Table 4-17 Short Plate Check and Limits (16196C)

Parameter	Frequency	Limit (Absolute value)
100MHz	Rs	40m Ω ~ 180m Ω
	Ls	100pH ~ 600pH
1GHz	Rs	120m Ω ~ 570m Ω
	Ls	50pH ~ 350pH


Table 4-18 Short Plate Check and Limits (16196D)

Parameter	Frequency	Limit (Absolute value)
100MHz	Rs	30m Ω ~ 260m Ω
	Ls	50pH ~ 600pH
1GHz	Rs	80m Ω ~ 860m Ω
	Ls	0pH ~ 350pH

5 Specifications and Supplemental Performance Characteristics

This chapter provides specifications and supplemental performance characteristics of the 16196A/B/C/D test fixture.

Specifications

Applicable Instruments		Refer to the Table 1-5 .
Applicable DUT Type		Surface Mount Device with side electrodes.
	Model	Length (L) × Width (W) × Height (H)
	16196A	$(1.6 \pm 0.15) \times (0.8 \pm 0.15) \times (0.4 \text{ to } 0.95) \text{ mm}$
	16196B	$(1.0 \pm 0.1) \times (0.5 \pm 0.1) \times (0.3 \text{ to } 0.6) \text{ mm}$
	16196C	$(0.6 \pm 0.03) \times (0.3 \pm 0.03) \times (0.27 \text{ to } 0.33) \text{ mm}$
	16196D	$(0.4 \pm 0.02) \times (0.2 \pm 0.02) \times (0.11 \text{ to } 0.22) \text{ mm}$
Frequency		DC to 3GHz
Maximum Voltage		$\pm 42\text{V}$ peak max. (AC+DC)
Maximum Current		5 A
Operating Environment	temp.	-55°C to +85°C
	humidity	15% to 95%RH (@ wet bulb temp. < 40°C)
Non Operating Environment	temp.	-55°C to +85°C
	humidity	$\leq 90\%$ RH (@ wet bulb temp. <65°C)
Dimension		78 (D) x 140 (W) x 48 (H) mm (nominal)
Weight		250g (nominal)
		Model (nominal) 16196A 26.2mm 16196B 26.9mm 16196C 27.1mm 16196D 27.3mm
Safety Standards		IEC 61010-1:2001 / EN 61010-1:2001 Canada: CAN/CSA C22.2 No. 1010.1-92 Installation/overvoltage category II Pollution degree 2 Indoor use

Supplemental Performance Characteristics

This section provides useful data on the 16196A/B/C/D. These supplemental performance characteristics should not be considered specifications.

Additional Error

Additional errors are calculated as follows.

|Z| Measurement

Additional error for Impedance Z_e [%] is calculated by substituting the values in the table below into the following equation.

$$Z_e [\%] = \pm \{A + (Z_s/Z_x + Y_o \times Z_x) \times 100\}$$

where

A [%] Test Fixture's Proportional Error [%]

Y_o [S] Test Fixture's Open Repeatability [S]

Z_s [Ω] **Test Fixture's Short Repeatability [Ω]**

Z_x [Ω] Measured Impedance Value of DUT [Ω]

Z_s	$(30 + 125 \times f) \times 10^{-3} [\Omega]$
Y_o	$(5 + 40 \times f) \times 10^{-6} [S]$
A	$1 \times f^2 [\%]$

where f is frequency (GHz).

D Measurement

Additional error for Dissipation Factor D_e is calculated by using the additional error for Impedance Z_e [%] as follows.

If $D_x \leq 0.1$:

$$D_e = Z_e / 100$$

If $0.1 < D_x \leq 0.5$:

$$D_e = (Z_e / 100) \times (1 + D_x)$$

where D_x is the measured value of D . It is necessary for Z_e to be below 10%.

NOTE

D is not expressed as a percentage but as an absolute value.

Rs (ESR) Measurement

Additional error $Rse[\%]$ of the R_s measurement is calculated by using the additional error for Impedance $Ze [\%]$ as follows.

If $Dx \leq 0.1$:

$$Rse [\%] = Ze / Dx$$

If $0.1 < Dx \leq 0.5$:

$$Rse [\%] = (Ze / Dx) \times \sqrt{1 + Dx^2}$$

Dx is the measured value of D and is calculated as follows.

$$Dx = 2 \times \pi \times f \times Csx \times Rsx,$$

where


f : measurement signal frequency

Csx : measured value of Cs

Rsx : measured value of R_s .

Figure 5-1

Additional Error for Impedance



Residual Inductance

Residual inductance for the Short Plate is as follows.

Model	Residual Inductance [nH]
16196A	0.43
16196B	0.27
16196C	0.16
16196D	0.11

Applying loading weight to the DUT

The following table shows the factory default of loading weight on the DUT for each model. For the 16196D, the user can replace a part (washer) inside the cap to change it. For the 16196A/B/C, however the loading weight on the DUT cannot be changed.

Keysight Model Number	Loading weight to the DUT [gf]
16196A/B/C	400
16196D	300

Changing the loading weight to the DUT for the 16196D

If the factory default loading weight damages the DUT, replace the part (washer) inside the cap, which changes the spring pressure, to adjust the loading weight on the DUT. Replacement washers must be prepared by users themselves.

NOTE

When the washer is replaced, the specifications and performance of this product are not guaranteed.

Information required to create washers is given below.

Table 5-1

Material and size of the washer

Material	Outer diameter [mm]	Inner diameter [mm]
Polyacetal	φ8.0 to φ12.0	φ3.2

Figure 5-2 Shape of the cap washer




Table 5-2 Relation between washer thickness and loading weight applied to the DUT (design values)

t [mm]	Loading weight to the DUT:G [gf]
1.0	120
1.5	180
2.0	240
2.5	300

The loading weight applied to the DUT, G [gf], is obtained by substituting the values of t [mm] into the following equation.

$$G \text{ [gf]} = 119 \times (3.55 + t) - 420$$


NOTE

If a washer with a thickness (t) of less than 1.0 mm is used, measurement may not be performed accurately.

Replacing the washer inside the cap

The procedure for replacing the washer inside the cap is described below.

Figure 5-3 Exploded view of the cap



16196abcdoj4005

Replacement procedure

1. Locate a replacement washer.
2. Detach the cap from the fixture.
3. Detach [1] then [2] while holding [7].
4. Detach [3] and [4] from [7].
5. Detach [5] from [7], and replace it with the replacement washer.
6. Attach [4] detached in Step 4 to [7].
7. While protruding [7] from [3], attach [2] detached in Step 3, and tighten [1] with a tightening torque of 0.2 Kgf-cm (0.2 in-lb).
8. Clean [7]. (See **“User Maintenance”** of the **Chapter 4, “Cleaning.”**)

NOTE

Be careful not to bolt inside parts out of the cap when detaching/attaching [1] and [2], because the spring [6] is powerful.

6 Service

This chapter describes the proper maintenance of the fixture and parts replacement.

Serial Number for Non-RoHS Test Fixture:

16196A: “MY43100001 – MY43200366” or “SG43100001 – SG43200366”

16196B: “MY43100001 – MY43200332” or “SG43100001 – SG43200332”

16196C: “MY43100001 – MY43200358” or “SG43100001 – SG43200358”

16196D: “MY43100001 – MY45200319” or “SG43100001 – SG45200319”

Serial Number for RoHS Test Fixture:

16196A: “MY43200367 and above” or “SG43200367 and above”

16196B: “MY43200333 and above” or “SG43200333 and above”

16196C: “MY43200359 and above” or “SG43200359 and above”

16196D: “MY45200320 and above” or “SG45200320 and above”

Replaceable Parts


Check the part number by the exploded view below. Do not disassemble the fixture beyond what is shown in this exploded view.

To order parts, use the Keysight part numbers listed in **Table 6-1** until **Table 6-4**. If a faulty part is located in an assembly that cannot be disassembled, order the next higher assembly or return the fixture to the nearest Keysight Technologies Sales/Service Office for repair or replacement.

Shown are the support parts for RoHS and non-RoHS compliance 16196A/B/C/D Parallel Electrode SMD Test Fixture, DC to 3 GHz. All the listed items are changed at RoHS conversion. Due to limited availability of RoHS compliance station and technical difficulties in RoHS soldering, only parts and support level that do not require RoHS soldering are supported. Once the non-RoHS support part is depleted, please proceed to obtain the RoHS compliant support part.

Block Assembly

Figure 6-1 Block Assembly Exploded View



16196abcdoj4006

Table 6-1

Replaceable Parts (Block Assembly)

Ref /D	Keysight Part No	Description	Qty	RoHS Compliant Replacement Part	Description	Qty
1	16196-60010	Cap Assembly (for 16196A/B/C)	1	16196-60010	Cap Assembly (for 16196A/B/C)	1
	16196-60020	Cap Assembly (for 16196D)	1	16196-60020	Cap Assembly (for 16196D)	1
2	0515-1044	Cap Screw Mach M1.6	2	0515-1044	Cap Screw Mach M1.6	2
3	16196-60112	φ1.34 Insulator (for 16196A)	1	16196-60112	φ1.34 Insulator (for 16196A)	1
	16196-60113	φ1.14 Insulator (for 16196A)	1	16196-60113	φ1.14 Insulator (for 16196A)	1
	16196-60114	φ1.08 Insulator (for 16196A)	1	16196-60114	φ1.08 Insulator (for 16196A)	1
	16196-60212	φ0.85 Insulator (for 16196B)	1	16196-60212	φ0.85 Insulator (for 16196B)	1
	16196-60213	φ0.75 Insulator (for 16196B)	1	16196-60213	φ0.75 Insulator (for 16196B)	1
	16196-60214	φ0.68 Insulator (for 16196B)	1	16196-60214	φ0.68 Insulator (for 16196B)	1
	16196-60312	φ0.48 Insulator (for 16196C)	1	16196-60312	φ0.48 Insulator (for 16196C)	1
	16196-60412	φ0.34 Insulator (for 16196D)	1	16196-60412	φ0.34 Insulator (for 16196D)	1
	16196-60414	φ0.30 Insulator (for 16196D)	1	16196-60414	φ0.30 Insulator (for 16196D)	1
4	N/A	Ground Assembly	1	N/A	Ground Assembly	1
5 ¹	16196-60111	Lower Electrode (for 16196A)	1	16196-60111	Lower Electrode (for 16196A)	1
	16196-60211	Lower Electrode (for 16196B)	1	16196-60211	Lower Electrode (for 16196B)	1
	16196-60311	Lower Electrode (for 16196C)	1	16196-60311	Lower Electrode (for 16196C)	1

Table 6-1

Replaceable Parts (Block Assembly)

Ref /D	Keysight Part No	Description	Qty	RoHS Compliant Replacement Part	Description	Qty
	16196-60411	Lower Electrode (for 16196D)	1	16196-60411	Lower Electrode (for 16196D)	1
6	0515-0954	Screw M-2.5	3	0515-2975	Screw M-2.5	3
7	16196-24001	Base	1	16196-24001	Base	1
8	0515-0905	Screw M-2.5	3	0515-1940	Screw M-2.5	3
9	16196-24004	Push Ring	1	16196-24004	Push Ring	1
10	16196-29002	Open Plate	1	16196-29002	Open Plate	1
11 ¹	16196-29026	Short Plate (for 16196A)	1	16196-29026	Short Plate (for 16196A)	1
	16196-29027	Short Plate (for 16196B)	1	16196-29027	Short Plate (for 16196B)	1
	16196-29028	Short Plate (for 16196C)	1	16196-29028	Short Plate (for 16196C)	1
	16196-65101	Short Plate (for 16196D)	1	16196-65101	Short Plate (for 16196D)	1
12	16196-00601	Plate (for 16196A)	1	16196-00601	Plate (for 16196A)	1
	16196-00611	Plate (for 16196B)	1	16196-00611	Plate (for 16196B)	1
	16196-00621	Plate (for 16196C)	1	16196-00621	Plate (for 16196C)	1
	16196-00632	Plate (for 16196D)	1	16196-00632	Plate (for 16196D)	1

1. Maintenance Kit consisting of 5 replaceable parts is available. Refer to **"Maintenance Kit" on page 67** for details.

Cap

Figure 6-2 Cap Exploded View (for 16196A/B/C)




Table 6-2 Replaceable Parts (Cap)

Ref /D	Keysight Part No.	Description	Qty	RoHS Compliant Replacement Part	Description	Qty
1	0515-1044	Screw Mach M1.6	1	0515-1044	Screw Mach M1.6	1
2	16196-24005	Stopper	1	16196-24005	Stopper	1
3	N/A	Cap	1	N/A	Cap	1
4	1460-2618	Spring	1	1460-2618	Spring	1
5 ¹	16196-23008	Upper Electrode	1	16196-23008	Upper Electrode	1

1. Maintenance Kit including 5 replaceable parts is available. Refer to **“Maintenance Kit”** on page 67 for details.

Figure 6-3 Cap Exploded View (for 16196D)




Table 6-3 Replaceable Parts (Cap)

Ref /D	Keysight Part No.	Description	Qty	RoHS Compliant Replacement Part	Description	Qty
1	0515-1077	Screw Mach M2	1	0515-1077	Screw Mach M2	1
2	3050-2238	Washer	1	3050-2238	Washer	1
3	N/A	Cap	1	N/A	Cap	1
4	3050-2241	Washer	1	3050-2241	Washer	1
5	3050-2239	Washer	1	3050-2239	Washer	1
6	1460-2618	Spring	1	1460-2618	Spring	1
7 ¹	16196-23043	Upper Electrode	1	16196-23043	Upper Electrode	1

1. Maintenance Kit including 5 replaceable parts is available. Refer to **“Maintenance Kit”** on page 67 for details.

Other Parts

Table 6-4 Replaceable Parts (Other Parts)

Ref /D	Keysight Part No.	Description	Qty	RoHS Compliant Replacement Part	Description	Qty
1	16196-60150	Carrying Case (for 16196A)	1	16196-60150	Carrying Case (for 16196A)	1
	16196-60250	Carrying Case (for 16196B)	1	16196-60250	Carrying Case (for 16196B)	1
	16196-60350	Carrying Case (for 16196C)	1	16196-60350	Carrying Case (for 16196C)	1
	16196-60450	Carrying Case (for 16196D)	1	16196-60450	Carrying Case (for 16196D)	1
2	16193-60002	Magnifying Glass	2	16193-60002	Magnifying Glass	2
3	5182-7586	Cleaning Rod	1	5182-7586	Cleaning Rod	1
4	8710-0909	Wrench 1.5 mm Hex	1	8710-0909	Wrench 1.5 mm Hex	1
5	8710-2081	Tweezers	1	8710-2081	Tweezers	1
6	1540-0622	Case for OPEN and SHORT plate	1	9300-2603	Case with Cap	1
7	9282-0114	Cushion	1	16196-25614	Cushion	1

Maintenance Kit

The 16196U-maintenance kit is available to provide consumable products and replaceable parts for the 16196A/B/C/D.

16196U Maintenance Kit

The 16196A/B/C/D common option and options for each model separately are available.

Table 6-5 16196A/B/C Common Option

Opt010	Upper Electrode Set for 16196A/B/C (5 pieces)
--------	---

Table 6-6 16196A Option

Opt100	1608(mm) Short Plate Set (5 pieces)
Opt110	1608(mm) Lower Electrode Set (5 pieces)

Table 6-7 16196B Option

Opt200	1005(mm) Short Plate Set (5 pieces)
Opt210	1005(mm) Lower Electrode Set (5 pieces)

Table 6-8 16196C Option

Opt300	0603(mm) Short Plate Set (5 pieces)
Opt310	0603(mm) Lower Electrode Set (5 pieces)

Table 6-9 16196D Option

Opt020	Upper Electrode Set for 16196D (5 pieces)
Opt400	0402(mm) Short Plate Set (5 pieces)
Opt410	0402(mm) Lower Electrode Set (5 pieces)

Replacement Procedure


This section describes the replacement methods for the lower electrode, insulator and upper electrode. After replacing the respective parts, check the operation of the parts with reference to "Operation Check."

To replace the insulator and upper electrode, the 1.5-mm hex wrench (Keysight Part No. 8710-0909), included with the fixture, is required.

Lower Electrode

1. Prepare the replacement center electrode.
2. Take out the 3 screws from the bottom of the fixture and take out the DUT insert.


Figure 6-4 Removing the Bottom of the Fixture



3. Remove the lower electrode from the DUT insert.

Figure 6-5

Removing the Lower Electrode




4. Insert the replacement lower electrode in the DUT insert.

NOTE

The tip of the lower electrode is thin and easily bent. To prevent the tip of the lower electrode from contacting the inside of the DUT insert and being bent, insert the lower electrode vertically against the DUT's bottom surface.

5. Insert the DUT insert in the bottom of the fixture so that the bottom screws settle into the holes in the bottom of the fixture.

Figure 6-6 Mounting the DUT Insert



6. Fasten the DUT insert to the bottom of the fixture using the screws.

Insulator

Replace the insulator with reference to **“Selecting and Changing the Insulator Assembly” on page 20.**

Upper Electrode

1. Prepare the replacement electrode.
2. Remove the cap from the fixture.
3. Take out the screw from the top of the cap and remove the electrode from the cap.


NOTE

In case of the 16196D, take out the screw from the top of the cap while holding the electrode.

4. Take the electrode out of the spring and insert the replacement electrode.
5. Push the electrode in from the bottom of the cap so that the top of the electrode protrudes out of the top of the cap.

Figure 6-7

Electrode Replacement 1



16196abcj0508


6. Place the stopper removed in step 3 so that the protrusion in the bottom aligns with the indent in the top of the electrode and tighten the screw.

NOTE

In case of the 16196D, while holding the electrode, attach the washer and tighten the screw. The tightening torque is 0.2 Kgf-cm (0.2 in-lb).

Figure 6-8

Electrode Replacement 2



Assembling Check

The assembling check need to be performed following replacement of parts. The impedance measurement instrument or the network analyzer is required for the assembling check. The impedance measurement instrument is more recommendable. Refer to “**Assembling Check**” on page 46 for the procedure using the impedance measurement instrument.

The assembly check methods with the network analyzer are explained in the following.

NOTE

The network analyzer can be used only for the assembling check. The network analyzer has no function to measure DUT with the 16196A/B/C/D.

Method Using Network Analyzer

Required Tools

- Keysight general network analyzer (example: 8753E, E5061B, E5063A etc.)
- Open plate
- Short plate

Procedure

Step 1. Conduct S11 full-calibration with the 7-mm connector to be connected to the fixture.

NOTE

The S11 full-calibration must be always performed before connecting the fixture. For details on the calibration method, see the User's Guide for the measuring instrument.

Step 2. Connect the fixture to the measuring instrument.

Step 3. Remove the cap and place the open plate on the insulator assembly. Then attach and fasten the cap.

Step 4. Set the measuring instrument as follows.

Measurement Parameter	Primary:Mag, Secondary:Phase
Power	−10dBm
IF BW	100Hz
Point Averaging	16

Port Extension	16196A: 26.2mm
	16196B: 26.9mm
	16196C: 27.1mm
	16196D: 27.3mm

NOTE

For details on the setting and measurement procedures, see the User's Manual for the measuring instrument.

- Step 5.** Take Mag and Phase value readings at 100MHz and 1GHz and record the results. Check if the Mag and Phase values are within the typical value ranges shown in the following table.

Table 6-10 Operation Check Typical Values (Open, common for 16196A/B/C/D)

Parameter	Frequency	Typical Value (Absolute value)
Mag	100MHz	-0.2 ~ 0.2
Mag	1GHz	-0.2 ~ 0.2
Phase	100MHz	-0.5° ~ 0.5°
Phase	1GHz	-2.5° ~ 2.5°

- Step 6.** Remove the open plate, and place the short plate on the insulator assembly. Then attach and fasten the cap.

- Step 7.** Take Mag and Phase value readings at 100MHz and 1GHz in this short state and record the results. Check if the Mag and Phase values are within the typical value ranges shown in the following table.

Table 6-11 Operation Check Typical Values (Short, 16196A)

Parameter	Frequency	Typical Value (Absolute value)
Mag	100MHz	-0.06 ~ -0.01
Mag	1GHz	-0.18 ~ -0.03
Phase	100MHz	178° ~ 180°
Phase	1GHz	171° ~ 178°

Table 6-12 Operation Check Typical Values (Short, 16196B)

Parameter	Frequency	Typical Value (Absolute value)
Mag	100MHz	-0.06 ~ -0.01
Mag	1GHz	-0.19 ~ -0.04

Table 6-12 Operation Check Typical Values (Short, 16196B)

Parameter	Frequency	Typical Value (Absolute value)
Phase	100MHz	179° ~ 180°
Phase	1GHz	174° ~ 180°

Table 6-13 Operation Check Typical Values (Short, 16196C)

Parameter	Frequency	Typical Value (Absolute value)
Mag	100MHz	-0.07 ~ -0.01
Mag	1GHz	-0.20 ~ -0.04
Phase	100MHz	179° ~ 180°
Phase	1GHz	174° ~ 180°

Table 6-14 Operation Check Typical Values (Short, 16196D)

Parameter	Frequency	Typical Value (Absolute value)
Mag	100MHz	-0.15 ~ 0
Mag	1GHz	-0.40 ~ 0
Phase	100MHz	179° ~ 180°
Phase	1GHz	174° ~ 180°

Numerics

16196A Option, 74
 16196A/B/C Common Option, 74
 16196B Option, 74
 16196C Option, 74
 16196D Option, 74
 16196U Maintenance Kit, 74
 7-mm connector, 16

A

Accessories, 21
 adapter, 15
 Additional Error, 61
 Assembling Check, 53

B

Body Side Surfaces
 Cleaning Methods, 43

C

Cap

Cleaning Methods, 43
 Functions, 20
 Places Requiring Cleaning, 41
 Replaceable Parts, 69

Carrying Case

16196A Package Contents, 12
 16196B Package Contents, 13
 16196C Package Contents, 13
 16196D Package Contents, 14
 Replaceable Parts, 73

certification, 4

Changes The Spring Pressure, 63

Check Sheet

Fill-Out Example, 49

Cleaning

Methods, 42
 Places Requiring, 41

Cleaning Rod

16196A Package Contents, 12
 16196B Package Contents, 12
 16196C Package Contents, 13
 16196D Package Contents, 14
 Functions, 21

Replaceable Parts, 73

D

Dimension, 60
 Documentation Warranty, 4
 DUT
 Connecting and Measuring, 34
 Removing, 34
 DUT Insertion Hole
 Functions, 20

E

Electrical Length, 29
 Electrode Check, 53
 Electrode Structure, 19
 Electrode Wear Check
 Check Sheet, 50
 Fill-Out Example, 49
 Procedure, 48
 Reference Value Acquisition, 46

F

Fixture Compensation, 30
 Frequency
 Specifications, 60
 Functions, 20

I

Insulator Assembly

16196A Package Contents, 12
 16196B Package Contents, 12
 16196C Package Contents, 13
 16196D Package Contents, 13
 Cleaning Methods, 42
 Functions, 21
 identifications, 22
 installing, 28
 Places Requiring Cleaning, 41
 Removing, 27
 Replaceable Parts, 69
 Selecting, 25
 Specifications, 25

L

Limit

Electrode Check, 54

Limits

Short Plate Check, 57

Lower Electrode

Cleaning Methods, 42

Places Requiring Cleaning, 41

Replaceable Parts, 69

Replacement Procedure, 76

Ls, 47, 48, 54

Electrode Check, 54

Electrode Wear Check, 48

Performance Check Representative Value,
82

Short Plate Check, 56

Short Plate Wear Check, 47, 48

M

Magnifying Glass

16196A Package Contents, 12

16196B Package Contents, 13

16196C Package Contents, 13

16196D Package Contents, 14

Functions, 20

Replaceable Parts, 73

Maintenance Items, 39

Maintenance Kit, 74

Mark, 22

Maximum Current, 60

Maximum Voltage, 60

N

Non Operating Environment, 60

O

Open Compensation, 30

Open Plate

16196A Package Contents, 12

16196B Package Contents, 12

16196C Package Contents, 13

16196D Package Contents, 13

Cleaning Methods, 42

Functions, 21

Open Compensation, 31

Places Requiring Cleaning, 41

Replaceable Parts, 69

Open Repeatability, 61

Operating Environment, 60

Operation and Service Manual

16196A Package Contents, 12

16196B Package Contents, 13

16196C Package Contents, 13

16196D Package Contents, 14

Opt010

16196A/B/C Common Option, 74

Opt020

16196D Option, 74

Opt100

16196A Option, 74

Opt110

16196A Option, 74

Opt200

16196B Option, 74

Opt210

16196B Option, 74

Opt300

16196C Option, 74

Opt310

16196C Option, 74

Opt400

16196D Option, 74

Opt410

16196D Option, 74

Option 710

16196A Package Contents, 12

16196B Package Contents, 13

16196C Package Contents, 13

16196D Package Contents, 14

P

Package Contents

16196A, 12

16196B, 12

16196C, 13

16196D, 13

Performance Check

Method Using Network Analyzer, 81

Push Ring

16196A Package Contents, 12

16196B Package Contents, 12

- 16196C Package Contents, [13](#)
- 16196D Package Contents, [14](#)
- Functions, [21](#)
- Removing the DUT, [35](#)
- Replaceable Parts, [69](#)

R

- Reference Value
 - Electrode Wear Check, [46](#)
- Replaceable Parts
 - Block Assembly, [69](#)
 - Cap, [71](#), [72](#)
 - Other Parts, [73](#)
- Residual inductance, [33](#), [63](#)
- Rs, [47](#), [48](#), [54](#)
 - Electrode Check, [54](#)
 - Electrode Wear Check, [48](#)
 - Performance Check Representative Value, [82](#)
- Short Plate Check, [56](#)
- Short Plate Wear Check, [47](#), [48](#)

S

- Safety Standards, [60](#)
- Short Compensation, [32](#)
- Short Plate
 - 16196A Package Contents, [12](#)
 - 16196B Package Contents, [12](#)
 - 16196C Package Contents, [13](#)
 - 16196D Package Contents, [14](#)
 - Cleaning Methods, [42](#)
 - Functions, [21](#)
 - Places Requiring Cleaning, [41](#)
 - Replaceable Parts, [69](#)
 - Residual inductance, [33](#), [63](#)
 - Short Compensation, [32](#)
- Short Plate Check, [56](#)
- Short Plate Wear Check
 - Check Sheet, [51](#)
 - Reference Value Acquisition, [47](#)
- Short Repeatability, [61](#)
- Specifications, [60](#)
- Supplemental Performance Characteristics, [61](#)

T

- Tweezers
 - 16196A Package Contents, [12](#)
 - 16196B Package Contents, [12](#)
 - 16196C Package Contents, [13](#)
 - 16196D Package Contents, [14](#)
 - Functions, [21](#)
 - Replaceable Parts, [73](#)

U

- Upper Electrode
 - Cleaning Methods, [42](#)
 - Places Requiring Cleaning, [41](#)
 - Replacement Procedure, [79](#)
- User Limit Values
 - Setting Example, [44](#)

W

- Wear Check, [44](#)
- Weight, [60](#)
- Wrench
 - 16196A Package Contents, [12](#)
 - 16196B Package Contents, [12](#)
 - 16196C Package Contents, [13](#)
 - 16196D Package Contents, [14](#)
 - Functions, [21](#)
 - Replaceable Parts, [73](#)

This information is subject to change without notice.

© Keysight Technologies 1999-2020

Edition 6, January 2020



16196-90040

www.keysight.com